CDPR Vehicle Maintenance Shop, Mill Creek Campground Del Norte Coast Redwood State Park Highway 101, South Crescent City, Del Norte County

*Notice of Proposed No Further Action* related to petroleum discharges. Comment Period ends May 25, 2002

Site History: The Site is located approximately 6 miles South of Crescent City, California. The topography of the area is mountainous at an approximate elevation range of 500 feet above mean sea level. On March 31, 1998, one, 1,000-gallon gasoline storage tank was removed. At the time of tank removal, some soil contamination was noted and the soil sample analysis results verified that observation. MtBE was detected in soil samples MCC-2 (36 ug/kg) and MCC-3 (250 ug/kg). Groundwater was 3.5 feet below grade and product was floating on the water.

Monitoring Activities: On February 13, 2001, Treadwell & Rollo installed monitoring wells TR-1, TR-2 and TR-3 to total depths of 15 below ground surface (bgs), 20 feet bgs. and 19 feet bgs, respectively. Materials encountered while drilling soil borings TR-1 through TR-3 consisted of gravelly clay to clay fill material to depths between 13 feet bgs and 18 feet bgs overlying weathered bedrock to the maximum explored depth of 20 feet bgs. The well screen for wells TR-1, TR-2, and TR-3 was installed from approximately 5 feet to 15 feet bgs, 5 feet to 20 bgs, and 4 feet to 19 feet bgs in each well, respectively.

Monitoring Results: No petroleum constituents were reported above the reporting limit for the soil samples submitted from the three soil borings. Groundwater has been found only in well TR-3. The analytical results for the groundwater samples collected during the one hydrological cycle (four consecutive quarters) report no concentrations of petroleum constituents above the reporting limits.

Sensitive Receptor Survey: Mill Creek is the closest surface water, approximately 1500 feet East of the site. The water supply for the site was pumped from Mill Creek and stored in the on-site wooden above ground storage tank. No registered water supply wells are known within the campground area.

Related documents and file information are available for review until May 17, 2002. Please contact Ron Allen (aller@rb1.swrcb.ca.gov) with any questions.

Unless additional comments are received with significant new information, the Regional Water Board staff plans to concur with no further action upon close of the comment period.